

- Venting must be in accordance with local codes and the National Fuel Gas Code Z22
- Minimum vent length is 3 feet
- Heater connection size is 4" diameter for all models listed, a 4-3 reducer is required for 3" ducting
- 3 Year Parts

CLEARANCES:

Vent cap is required

12" from wall to terminal cap. Beyond 12" requires additional support

3 feet minimum distance to overhang above

6 feet minimum to adjoining building

1" Clearance from Class B pipe

6" Clearance from Class C Pipe

Read Installation Manual for all Clearances.

-
- Venting must be in accordance with local codes and the National Fuel Gas Code Z22
 - Minimum vent length is 3 feet
 - Heater connection size is 4" diameter for all models listed, a 4-3 reducer is required for 3" ducting
 - 3 Year Parts

CLEARANCES:

Vent cap is required

Min 6" (heat) to max 12" (wind) from wall to terminal cap. Beyond 12" requires additional support

3 feet minimum distance to overhang above

6 feet minimum to adjoining building

1" Clearance from Class B pipe

6" Clearance from Class C Pipe